## Sealed Bid #14014 - Golf Course Pumping Station

		Pumps, Motors & Controls, Inc.	Precise Control	Pump Mechanical Technical Services, LLC
Item	Description			
	Make/Model	PMCI model 1800 VSVT-Four	Flowtronex VWTP-1800-4-110	Motor Controls, Inc./American Turbine
1	Materials	\$80,750.00	\$87,676.00	\$77,300.00
2	Installation	\$2,500.00	included	\$8,900.00
	Total:	\$83,250.00	\$87,676.00	\$86,200.00
	Delivery	60 days aro 1 yr from date of shipment - repair or replace defects or design, less transportation; Extended	·	40 days aro
	Warranty	options available	1 yr, no extended options	Motors 3 yrs; VFD 6 yrs; Station 2 yrs; Extended options as required
	Installation	included in 60 days		4 days
		,	30% deposit required; Balance due Net 30 from	·
	Terms:	50% deposit; balance due at installation	receipt of invoice	Not stated
Specif	ication Exceptions:			
		Section 1 a: not 3 1/2" silicone filled pressure gauges  Section 2 a: no U.L. listing of complete pump station Section 2 f: no Microprocessor controller with SMOOTHFLOW VII control software  Section 2 r: no S.L.A.P U.L. category B & C surge, etc. Section 2 z: no touch-screen interface terminal for viewing flow, etc.  Section 2 aa: no access to flowtronex customer servce telephone support  Section 3 b: No column assy: 6' x 1 1/4" for 12' total pump length, etc.		Section 1 a: exceeds 4 1/2", not 3 1/2" Section 1h: exceeds as iron phosphate zinc primer w/oven cured polyester powder coat  Section 2c: Exceeds 100KA Section 2e: Exceeds 100 KA Section 2f: exceeds Compalt logic Section 2i: exceeds dual 3 1/2" line reactor Section 2r: exceeds UL Type 1 750V letter Section 2t: exceeds dual non _ resettable
		See Exceptions to specifications included with bid		Section 2z: exceeds N4 640 x 480 resolution 18 bit  Section 2bb: MCI Tech Support  Section 2 cc: PMTS Tech Support  Section 3d: exceeds high efficiency

Information reflects pricing only and other factors may be considered during the evaluation process