

## PRETREATMENT REQUIREMENTS

GREASE INTERCEPTORS OR OTHER PRETREATMENT DEVICES WILL BE REQUIRED FOR THE FOLLOWING FACILITIES:


- METAL FINISHING AND FABRICATION FACILITIES
   TRUCK WASHING FACILITIES, INCLUDING EXTERIOR
- COMMERCIAL CAR WASHES
- RESTAURANTS
   LABORATORIES
- BAKERIES AND COMMISSARIES
   MEDICAL FACILITIES
   COMMERCIAL LAUNDRIES
- OR, ANY FACILITY THAT WILL HAVE FLOOR DRAINS
- INDICATED ABOVE: THE FOLLOWING STANDARDS WILL APPLY TO FACILITIES

HOWEVER, ANY SERVICE LINE
THAT IS 6" IN DIAMETER OR MORE AND IS 6" (FT.) IN DEPTH
WILL BE REQUIRED TO A MINIMUM 15" SAMPLE WELL, WILL BE STANDARD FOR INDUSTRIAL FACILITIES HAVING A SERVICE LINE 6" IN DIAMETER OR LESS, HAVE A 24" SAMPLE WELL


THE SAMPLE WELL MUST BE INSTALLED BETWEEN THE PRETREATMENT FACILITY (GREASE TRAP) AND SEWER LINE TO CITY

REFERENCE. A BOLTED STEEL COVER SHOULD BE INCLUDED TO THE SPECIFICATION ATTACHED FOR YOUR SPECIFICATIONS FOR THE 15" AND 24" SAMPLE WELLS ARE AS AN OPTION WHEN AN ODOR PROBLEM IS LIKELY TO






N.T.S.



23 3/16\*

PLAN VIEW N.T.S.

SAMPLE WELL COVER INPAVED AREAS N.T.S.



NACHINED SURFACE MACHINED SURFACE-년0 3/16**\*** 3/16′-

### SPECIFICATIONS

SECTIONAL RISER TO REQUIRED DEPTH 4500 PSI AT 28 DAYS. UNIT IS OF MONOLITHIC CONSTRUCTION AT FLOOR AND FIRST STAGE OF WALL WITH 2. C.I. CASTINGS: CAST IRON FRAMES AND GRATES ARE I. CONCRETE: CLASS 1 CONCRETE OF DESIGN STRENGTH OF

MANUFACTURED OF GREY CAST IRON CONFORMING TO

ASTM A48-78 CLASS 3D, HEAVY-DUTY AASHTO H-20

## DETAIL, COVER & NOTES SAMPLE WELL

# DETAIL SHEET

N.T.S.

- NOTES:

  1. SAMPLING WELL MUST BE INSTALLED UNDER A SEPARATE PLUMBING PERMIT.
- 2. USE 15" T&G R.C.P. FOR INSTALLATION FOR
- INSTALLATION 5'-0" DEEP AND LESS.
- 6'-0" DEEP. USE 24" T&G R.C.P. FOR INSTALLATION GREATER THAN
- (STD RING AND M.H. COVER REQUIRED)
  4. SAMPLING WELL MUST BE SET IN A CIRCULAR OR SQUARE
- CONCRETE PAD
- INSTALLATION IS (1'-0" GREATER THAN OUTSIDE DIAMETER OF PIPE)
  5. INSIDE INSTALLATION NOT PERMITED WHERE OUTSIDE
- POSSIBLE.
- PLACE (15"MIN). 6. INSTALLATION INSIDE BUILDING MUST BE POURED IN
- NO CONCRETE PIPE IS PERMITTED. (AIR-TIGHT COVER REQUIRED)
- GRADE. 7. LAWN INSTALLATION MUST BE 4" ABOVE FINISHED
- 8. DRIVE AND SIDEWALK INSTALLATION MUST BE BROUGHT
- TO FINISHED GRADE.

  9. TO BE INSTALLED ON PRIVATE PROPERTY IN AN ACCESSIBLE LOCATION TO CITY PERSONNEL.

LP-DTL-SAN-041